

Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire Officer
Andhra Pradesh,

To:
District Educational Officer,
Anantapur

File No: 30498/ATP/DFO/2026, Date:07/03/2026

Occupancy NoC RC Number: 1611/B2/2012

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Sri Aurobindo Centenary School, represented by M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Ananthapuramu District.** - Regarding,

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 1611/B2/2012, Dt.20/06/2012
 4. Renewal NOC For Occupancy 1611/B2/2012, Dt.20/06/2020
 5. Online Application for Renewal NOC of M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Ananthapuramu District. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 05-03-2026.

-- X --

The Management of Sri Aurobindo Centenary School, represented by M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Anantapuramu District, has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.49200/- vide challan No. 91381037362025, Dated 26/02/2026 at CFMS, Online.

Sri Aurobindo Centenary School

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **M.Meenakshi Naidu D.No.15/608, Sy.No.604,Near Water Works ,Tadipatri, Anantapuramu District.**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

