

3/7/26, 11:59 AM

A.P. State Disaster Response and Fire Services Department

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:
District Disaster Response & Fire Officer
Andhra Pradesh,

To:
District Educational Officer,
Anantapur

File No: 30498/ATP/DFO/2026, Date:07/03/2026

Occupancy NoC RC Number: 1611/B2/2012

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Sri Aurobindo Centenary School, represented by M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Ananthapuramu District.** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 1611/B2/2012, Dt.20/06/2012
 4. Renewal NOC For Occupancy 1611/B2/2012, Dt.20/06/2020
 5. Online Application for Renewal NOC of M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Ananthapuramu District. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 05-03-2026.

-- X --

The Management of Sri Aurobindo Centenary School, represented by M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Anantapuramu District. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.49200/- vide challan No. 91381037362025, Dated 26/02/2026 at CFMS, Online.

Sri Aurobindo Centenary School

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **M.Meenakshi Naidu D.No.15/608, Sy.No.604,Near Water Works ,Tadipatri, Anantapuramu District.**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

- This Periodical Renewal Fire Certificate is valid from 20/06/2025 to 19/06/2030.
- The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91381037362025	2026-02-26	49200

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The management-maintained Fire Fighting Equipment as per Occupancy NOC as stated by the inspection Committee. The responsibility lies with the management to maintain firefighting equipment as seen during the inspection at all times. Any deviation founds during renewal period the NOC deemed to be cancelled. This certificate is issued in Fire Safety point of view only, but not for claiming any rights on the property.

"UNITE TO IGNITE, A FIRE SAFE INDIA"

"అగ్ని సురక్షిత భారతదేశానికి ఐక్యమవ్వండి"



Your Sincerely,

[Signature]
District Disaster Response & Fire Officer,
Anantapur District

In case of emergency, please call 101 or 08558 - 222299 or 9963739608

Copy to Management M.Meenakshi Naidu, D.No.15/608,Sy.No.604,Near Water Works ,Tadipatri, Anantapuramu District.

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

Medikond Digitally signed

by Medikonda

Meenakshi

Naidu

Date: 2026.09.09

11:18:53 +05'30'

https://stgfire.ap.gov.in/noc.html/final_noc_r/146404

Meenakshi

i Naidu

[Signature]
N.V. NEELIMA DEVI
Principal
Sri Aurobindo Centenary E.M. High School
TADIPATRI - 515 411
Affiliation No : 130686 School Code : 56461